

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE

LISTING No. 4485-0941:103

Page 1 of 1

CATEGORY: Opening Protection (Firestopping)

LISTEE: Minnesota Mining & Mfg. (3M), 3M Ctr, Bldg. 225-1S-02, St. Paul MN 55144
Contact: *Brandon Cordts (651) 733-5580 Fax (651) 737-2263

DESIGN: Models FIRE BARRIER CP 25WB+ caulk. Refer to listee's data sheet for detailed product description and operational considerations. Additional information may be found in the UL Fire Resistance Directory.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product designation, hourly rating and UL label.

APPROVAL: Listed as 1-hour to 3-hour fire-rated firestopping materials when constructed in accordance with UL Fire Resistance Directory.

*Rev. 06-12-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 26, 2007**

Listing Expires **June 30, 2008**

Authorized By: **MIKE TANAKA**, Senior Deputy State Fire Marshal
Program Manager