



January 24, 2006

3M Company
Mr. Brandon Cordts
3M Center, Building 207-1S-02
St. Paul, MN 55144-1000

Our Reference: 05NK29035, R9700


Subject: FireDam Spray 100 and FireDam Spray 200 Fill Materials

Dear Mr. Cordts:


This is to confirm that testing of the new FireDam Spray 200 fill material under Project 05NK29035, File R9700, has been completed and we have established Classification and Follow-Up Service on the new FireDam Spray 200 fill material in each of the joint systems, through-penetration firestop systems and perimeter fire containment systems in which the FireDam Spray 100 fill material was previously Classified.

The FireDam Spray 200 fill material was developed to replace the FireDam Spray 100 fill material. When we revised the various joint systems, through-penetration firestop systems and perimeter fire containment systems to include the FireDam Spray 200 fill material we also removed reference to the FireDam Spray 100 fill material. However, the Classification and Follow-Up Service on the FireDam Spray 100 fill material product has not yet been discontinued in order that you can use up existing inventories of product and continue to fill orders until the FireDam Spray 100 fill material product is phased out. Until that time, this is to confirm that the FireDam Spray 100 fill material is eligible for Classification in Joint System Nos. BW-S-0008, FF-D-0002, FF-D-0014, FF-D-1042, FW-D-0004, FW-D-0011, FW-D-1040, HW-D-0020, HW-D-0021, HW-D-0022, HW-D-0023, HW-D-0029, HW-D-0030, HW-D-0031, HW-D-0038, HW-D-0040, HW-D-0101, HW-D-0118, HW-D-0122, HW-D-0123, HW-D-0192, HW-D-0248, HW-D-0265, HW-D-0376, HW-D-0379, HW-D-0384, HW-D-0385 HW-D-1010, HW-D-1020 and HW-D-1059, in Perimeter Fire Containment System Nos. CW-S-2004, CW-S-2005 and CW-S-2007 and in Through-Penetration Firestop System Nos. C-AJ-1275, C-AJ-8106, W-L-8033 and W-L-8034

Very truly yours,


C. J. JOHNSON (Ext. 42649)
Lead Engineering Associate
Fire Protection Division

Reviewed by:


STEVEN J. HOFFMAN (Ext. 43353)
Staff Engineer
Fire Protection Division

