

Certificate of Compliance

Certificate Number **20070202-R9700**
Report Reference **2007 February 2**
Issue Date **2007 February 2**

Page 1 of 1



Issued to: **3M Company**
3M Center
St Paul, MN 55144


This is to certify that representative samples of **Batts and Blankets**
Duct Wrap 15A and 20A

Have been investigated by Underwriters Laboratories Inc.® (UL) or any authorized licensee of UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: ISO 6944-1985, "Fire Resistance Tests - Ventilation Ducts."


Additional Information: 3M FireBarrier Duct Wrap 15A for use in Ventilation System No. V-20.
3M FireBarrier Duct Wrap 20A for use in Ventilation System No. V-20.
3M FireBarrier Duct Wrap 15A Collar for use in Ventilation System No. V-20.
3M FireBarrier Duct Wrap 20A Collar for use in Ventilation System No. V-20.

Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.

The UL Classification Mark includes: UL in a circle symbol:  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product category name (product identity) as indicated in the appropriate UL Directory.

Look for the UL Classification Mark on the product

Issued by:

Mona Couloute
Underwriters Laboratories Inc.

Reviewed by:

Steven Hoffman
Underwriters Laboratories Inc.