



SECTION 11 81 29  
HORIZONTAL FALL PROTECTION

Display hidden notes to specifier. (Don't know how? [Click Here](#))

*Copyright 2016 - 2021 ARCAT, Inc. - All rights reserved*

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Fall Protection Horizontal Cable Systems
  - 1. Rooftop cable. (DBI-SALA RoofSafe Anchor and Cable System)

1.2 RELATED SECTIONS

- A. Section 07 50 00 - Membrane Roofing.
- B. Section 07 62 00 - Sheet Metal Flashing and Trim.
- C. Section 07 71 13 - Manufactured Copings.
- D. Section 07 72 13 - Manufactured Curbs.
- E. Section 07 91 23 - Backer Rods0 - Joint Sealants.

1.3 REFERENCES

- A. American National Standards Institute (ANSI):
  - 1. ANSI A10.32 - Personal Fall Protection Used in Construction and Demolition Operations.
  - 2. ANSI Z359.1 - Safety Requirements for Personal Fall Arrest Systems, Subsystems and Components.
  - 3. ANSI Z359.6 - Specifications and Design Requirements for Active Fall Protections Systems.
- B. ASTM International (ASTM):
  - 1. ASTM A123 / A123M - Standard Specification for Zinc (Hot-Dip Galvanized) Coatings

- on Iron and Steel Products.
  - 2. ASTM A747/A747M - Standard Specification for Steel Castings, Stainless, Precipitation Hardening.
  - 3. ASTM A36 - Standard Specification for Carbon Structural Steel.
  - 4. ASTM A500 - Standard Specification for Cold-Formed Welded and Seamless Carbon Steel Structural Tubing in Rounds and Shapes.
  - 5. ASTM A666 - Standard Specification for Annealed or Cold-Worked Austenitic Stainless Steel Sheet, Strip, Plate, and Flat Bar.
- C. American Welding Society (AWS):
- 1. AWS D1.1/D1.1M - Structural Welding Code - Steel.
- D. CSA Group (CSA):
- 1. CSA Z259.16 - Design of Active Fall Protection Systems.
  - 2. CSA W55.3 - Certification of companies for resistance welding of steel and aluminum.
  - 3. CSA W59 - Welded steel Construction.
- E. Occupational Safety and Health Administration (OSHA):
- 1. OSHA 29 CFR 1926.502 - Fall Prevention Systems and Criteria and Practices.
  - 2. OSHA 29 CFR 1910.29 General Industry.

#### 1.4 SUBMITTALS

- A. Submit under provisions of Section 01 30 00 - Administrative Requirements.
- B. Product Data: Manufacturer's data and product information indicating the sizes, descriptions, capacities, test certifications, and other descriptive data showing in sufficient detail that the product complies with the contract requirements.
- C. Shop Drawings: For fabrication showing the complete fall protection system. Layout drawings of each system in relation to the supporting structure indicating the locations of properly labeled components.
- D. Installer's Certification: Furnish proof of installer's current certification approval by manufacturer in the form of the installer's current certificate issued by the manufacture.
- E. Product Certificate: Containing the manufacturer's batch number on each individual component used in the systems.
- F. Qualifications Statement: For engineer performing delegated design.
- G. Systems Manual:
  - 1. Maintenance Procedures: Including parts list and maintenance requirements for all equipment.
  - 2. Operation Procedures: Indicating proper use of equipment for safe operation of the systems.
  - 3. Manufacturer's catalog data indicating the sizes, descriptions, capacities, test certifications, and other descriptive data showing sufficient detail that the product complies with the contract requirements.
- H. Record Documents: Include a copy of Record Drawings in the systems manual.
- I. Warranty: Submit manufacturer warranty.
- J. Delegated-Design Submittal: For fall protection system, including analysis data signed and sealed by the qualified professional engineer responsible for their preparation.

#### 1.5 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Minimum 25-year experience manufacturing similar products.
- B. Installer Qualifications: Minimum 2-year experience installing similar products, authorized, trained, and certified by manufacturer.
- C. Engineer for Delegated Design: Licensed in the jurisdiction and with a minimum of two years engineering fall protection systems.
- D. Coordination: Coordinate the installation of horizontal fall protection system with structural supports and finish materials.

#### 1.6 PRE-INSTALLATION MEETINGS

- A. Convene minimum two weeks prior to starting work of this section.

#### 1.7 DELIVERY, STORAGE, AND HANDLING

- A. Deliver materials in manufacturer's original unopened packaging. Store materials in original protective packaging. Prevent soiling, physical damage, or moisture.

#### 1.8 PROJECT CONDITIONS

- A. If required, coordinate layout and installation of framing and reinforcements for the fall protection system fixings and substrates.
- B. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's recommended limits.

#### 1.9 SEQUENCING

- A. Ensure that products of this section are supplied to affected trades in time to prevent interruption of construction progress.

#### 1.10 WARRANTY

- A. Manufacturer's 10-year minimum corrosion resistance and product warranty.

### PART 2 PRODUCTS

#### 2.1 MANUFACTURERS

- A. Acceptable Manufacturer: 3M Fall Protection Business, which is located at: 3833 Sala Way; Red Wing, MN 55066-5005; Toll Free Tel: 800-328-6146; Tel: 651-388-8282; Fax: 651-732-9244; Email:[request info \(3Mfallprotectionbusiness@mmm.com\)](mailto:request info (3Mfallprotectionbusiness@mmm.com)); Web:[https://www.3m.com/3M/en\\_US/p/c/ppe/fall-protection/i/safety/personal-safety/](https://www.3m.com/3M/en_US/p/c/ppe/fall-protection/i/safety/personal-safety/)
- B. Requests for substitutions will be considered in accordance with provisions of Section 01 60 00 - Product Requirements.
  - 1. If the system proposed uses an article, device, material, equipment, form of construction, fixture, or item other than the Basis of Design; provide certification that the proposed item is equal in quality, performance, and appearance, to the item specified.
- C. Source Limitation: Obtain fall protection system and components from a single manufacturer.

#### 2.2 FALL PROTECTION CABLE SYSTEMS; FORCE MANAGEMENT ROOF ANCHOR AND CABLE

- A. Basis of Design: DBI-SALA RoofSafe Anchor and Cable System as manufactured by 3M Fall

Protection. Rooftop horizontal cable fall protection system for rooftop maintenance including end anchors, intermediate cable supports, variable cable supports, traveler and corner cable supports as required.

1. Maximum span of 50 feet (15 m) between anchors and provides continuous hands free access for the user of the roof fall protection system.
2. Allow for multiple users, based on required system calculations.
3. Simultaneous Users: Up to 4 per sub span based on system design.
4. System shall not be used as a tieback anchor for facade maintenance.

B. Performance Requirements:

1. Delegated Design: Engage a qualified professional engineer, as defined in Section 01 40 00 - Quality Requirements.
2. Structural Performance: Fall protection systems shall withstand the effects of loads and stresses within limits and under conditions required by:
  - a. CSA Z259.16.
  - b. ANSI Z359.6
  - c. OSHA 1926.502.
  - d. Allow for multiple users, based on required system calculations.
  - e. Simultaneous Users: Up to 4 per sub span based on system design.
  - f. System capable of spanning 50 feet (15 m) between intermediate supports.
  - g. Allowable Force on Structure: 1,686 lbs. (7.5 kN) maximum.

C. Components:

1. Cable: 7x7, 5/16-inch (8 mm) 316 Stainless Steel Wire, Breaking Strength 8,542 lbs. (38 kN) minimum.
2. End Anchorage Connector: 316 Stainless Steel, electro-polished and Lot Numbered.
3. Tensioner: 180 lbs. (0.8 kN) 316 Stainless Steel.
4. Dampener: 180 lbs. (0.8 kN) 316 Stainless Steel with thermal cyclic loading.
5. Intermediate Guide: 316 Stainless Steel, electro-polished.
6. 90 and 45 Degree Corners: 316 Stainless Steel, electro-polished. Other angles are achieved using Variable Guide, spot welded.
7. Variable Guide: 316 Stainless Steel, electro-polished, spot welded.
8. Swage Toggles: 316 Stainless Steel, electro-polished.
9. Detachable Traveller: 8 mm. ASTM A747/A747M Precipitation Hardening Stainless Steel Casting, electro-polished and numbered. Double Locking for installation and removal, compatible D-ring for use with Saphook in accordance to ANSI Z359.1.
10. Finish type for modular end, corner, and intermediate anchors:
  - a. Anchorage Baseplates: Anodized aluminum plates designed and tested to be used with modular end, corner and intermediate anchors.

D. Materials:

1. Primary Cable Assembly Components: Stainless steel, ASTM A666, Type 316.
2. Aluminum: 6061 aluminum alloy.
3. Aluminum: 6082 aluminum alloy.

E. Fabricated Supports:

1. Carbon steel with corrosion resistant finish. Steel Plates, Shapes.
2. Bars: ASTM A36 Steel Tubing: ASTM A500, cold formed.
3. Welding rods and bare electrodes: Select according to AWS specifications or metal alloy welded.

F. Connectors:

1. Comply With:
  - a. OSHA regulation 1926.502.
  - b. ANSI Z359.1.
  - c. CSA Z259.12-11.

- G. Fabrication:
  1. Fabricate anchoring devices as recommended by the manufacturer to provide adequate support for intended use.
  2. Shop fabricate required anchorage posts using structural steel with material test certificates for full material traceability.
- H. Welding
  1. AWS structural specification D1.1 by certified welders.
  2. Fabricate joints in a manner to discourage water accumulation.
- I. Finishes:
  1. Stainless Steel: Electropolished for corrosion resistance.
  2. Structural Steel: Zinc Galvanized for corrosion resistance.
  3. Aluminum: Anodized.
  4. Aluminum: PVC coated.
- J. Accessories:
  1. Signage: Signs and system identification tags.
  2. Flashing: Comply with requirements of Section 07 62 00 - Sheet Metal Flashing and Trim "Sheet Metal Flashing and Trim."
  3. Flashing: Comply with requirements of Section 07 71 13 - Manufactured Copings "Roof Specialties."
  4. Flashing: Comply with requirements of Section 07 72 13 - Manufactured Curbs "Roof Accessories."
  5. Flashing: Comply with requirements of Section \_\_\_\_\_.
  6. Sealant: Comply with requirements of Section 07 91 23 - Backer Rods "Joint Sealants."

## PART 3 EXECUTION

### 3.1 EXAMINATION

- A. Examine areas and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of fall protection equipment.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 PREPARATION

- A. Coordinate location of fall protection equipment indicated to be attached to structural substrate or surface of roofing system and furnish anchoring devices with templates and diagrams.

### 3.3 INSTALLATION

- A. Only 3M or Certified Installers authorized in writing by 3M Fall Protection may make installation/repairs to this equipment. If the 3M Fall Protection Horizontal Lifeline System has been subject to fall force or inspection reveals an unsafe or defective condition, remove the system from service and contact 3M Fall Protection or a 3M Certified Installer regarding replacement or repair.
- B. Install according to approved shop drawings and manufacturer's instructions. Coordinate with work of other trades.
- C. Install anchorage and fasteners in accordance with manufacturer's recommendations to obtain the allowable working loads published in the product literature and in accordance with this specification.

- D. Exposed work shall be true to line and level with accurate angles, surfaces and with straight square edges. Coordinate anchorage system with supporting structure.
- E. Do not load or stress system until materials and fasteners are properly installed and ready for service.

### 3.4 FIELD QUALITY CONTROL

- A. Provide manufacturer's certified installer to inspect installed fall protection system. Ensure that system components operate as specified.

### 3.5 ADJUSTING

- A. Adjust fall protection components to function smoothly and safely.

### 3.6 CLEANING

- A. Clean the systems metal components with a soft brush, warm water, and a mild soap solution if needed after initial installation.
- B. Ensure all components are thoroughly rinsed with clean water after cleaning.

### 3.7 CLOSEOUT ACTIVITIES

- A. Demonstration: Demonstrate operation of system to Owner's personnel.
  - 1. Briefly describe function, operation, and maintenance of each component.
- B. Training: Train Owner's personnel on operation and maintenance of system.
  - 1. Use operation and maintenance manual as training reference, supplemented with additional training materials as required.
  - 2. Provide minimum of two hours of training.
  - 3. Provide training at the lifeline installation site.
  - 4. Training to take place at the completion of the installation.
- C. Do not use until trained in the use of the system

END OF SECTION