

CERTIFICATE OF COMPLIANCE

Certificate Number 20170505-R9700
Report Reference R9700
Issue Date 2017-May-05

Issued to: 3M Compnay
3M CENTER
SAINT PAUL, MN 55144-1001 USA

This is to certify that representative samples of FireDam 2000 Coating
Coatings, General Purpose

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 723, "Test for Surface Burning Characteristics of Building Materials."

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20170505-R9700
Report Reference R9700
Issue Date 2017-May-05

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

The following Surface Burning Characteristics are applicable only when the coating material are applied to the indicated surface at the indicated coverage.

Surface	1/4 in. Inorganic Reinforced Cement Board
	FireDam 2000 Coating
Flame spread	0
Smoke developed	15
Rate per coat (sq ft per gal)	500
Number of coats	1

Flash point of finished coating: Close cup, no flash to boiling.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

