



Certificate of Compliance



You have been awarded:

Intertek ETL Mark for Fire Resistant Products

IEEE 848 (1996): ASTM E1529 (2006): ASTM E1725 (2008): ISO 6944-1 (2008): ASTM E2336 (2004): ICC-ES AC101 (2001): ASTM E84 (2009): ASTM E84 (2010): ASTM E84 (2010b): ASTM E84 (2011a): ASTM E84 (2011b): ASTM E84 (2011c): ASTM E84 (2012): ASTM E814 (2011a): ASTM E119 (2012)

Certificate number: WHI17 – 20265301

This is a certificate of conformity to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.


Organization:

3M (Minnesota Mining and Manufacturing)
3M Center
St. Paul, MN 55144

Product: 3M Fire Barrier™ CP 25WB+ Caulk
SPEC ID 28792

Certification body: Intertek Testing Services NA, Inc.
Initial registration: May 26th, 2017
Date of expiry: May 26th, 2022
Issue status: 1

Dustin Behling
Certification Coordination Manager
Name


Signature

05/26/2017
Date

www.intertek.com

Registered address:
Intertek Testing Services NA, Inc. 545 E. Algonquin Rd. Arlington Heights, IL 60005 USA

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.