



8431 Murphy Drive
Middleton, WI 53562 USA

Telephone: 608.836.4400
Facsimile: 608.831.9279
www.intertek.com

Test Verification of Conformity

In the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the requirements of the referenced specifications at the time the tests were carried out. Intertek Testing Services NA, Inc is accredited under ISO/IEC 17025 for the test methods used and has met the guidelines in section 8 of CDPH v1.1

| | |
|---|---|
| Applicant Name & Address: | 3M Company 3M Center, 230-BS-39 St Paul, MN 55144 |
| Product: | 3M™ Fire Barrier Watertight Spray |
| Ratings & Principle Characteristics: | The results represent typical usage of the product 2.925 grams per foot spread onto 4.1 m ² within a private office or 11.89 m ² within a standard classroom. 3M™ Fire Barrier Watertight Spray complies with limits specified in CDPH v1.1 February 2010 for Targeted VOC and Formaldehyde limits in a private office and classroom. The sample had a measured range of total VOCs, per LEED v4 for total VOC and Target Chemical listed in CDPH v 1.1 Table 4-1, between 0.5 mg/m ³ and 5.0 mg/m ³ after 14 days. Contains 131.2 g/L VOC contents (less H2O and exempt solvents per SCAQMD Rule 1168) |
| Relevant Standards: | CDPH v1.1: Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers v1.1 SCAQMD Rule 1168 |
| Verification Issuing Office: | Intertek Testing Services NA, Inc. 8431 Murphy Drive Middleton, WI 53562 |
| Date of Tests: | December 23, 2016 – January 12, 2017 |
| Test Report Number(s): | 10241807MID-001a |

This verification is part of the full test report(s) and should be read in conjunction with them. This report does not automatically imply product certification.

Completed by: Bryan Bowman
Title: Chemist, BP Chemistry

Reviewed by: Mark Crawford
Title: Engineering Team Lead, BP Chemistry

Signature:

Signature:

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.