



8431 Murphy Drive  
Middleton, WI 53562 USA

Telephone: 608.836.4400  
Facsimile: 608.831.9279  
www.intertek.com

# Test Verification of Conformity

In the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the requirements of the referenced specifications at the time the tests were carried out. Intertek Testing Services NA, Inc is accredited under ISO/IEC 17025 for the test methods used and has met the guidelines in section 8 of CDPH v1.1

<b>Applicant Name &amp; Address:</b>	3M Company 3M Center, 230-BS-39 St Paul, MN 55144
<b>Product:</b>	3M™ Fire Barrier Water Tight Sealant 1000 NS
<b>Ratings &amp; Principle Characteristics:</b>	The results represent typical usage of the product as a 1/2 inch bead of caulk applied around floors, ceilings, walls, doors and windows at an application rate of 64.7 g of caulk per linear foot in a private office or standard classroom.  3M™ Fire Barrier Water Tight Sealant 1000 NS complies with limits specified in CDPH v1.1 February 2010 for Targeted VOC and Formaldehyde limits in a private office and classroom. The sample had a measured range of total VOCs, per LEED v4 for total VOC and Target Chemical listed in CDPH v 1.1 Table 4-1, of 0.5 mg/m <sup>3</sup> or less after 14 days.  Contains 47.3 g/L VOC contents (less H2O and exempt solvents per SCAQMD Rule 1168)
<b>Relevant Standards:</b>	CDPH v1.1: Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers v1.1  SCAQMD Rule 1168
<b>Verification Issuing Office:</b>	Intertek Testing Services NA, Inc. 8431 Murphy Drive Middleton, WI 53562
<b>Date of Tests:</b>	October 6-28, 2016
<b>Test Report Number(s):</b>	102677921MID-001d

This verification is part of the full test report(s) and should be read in conjunction with them. This report does not automatically imply product certification.

**Completed by:** Bryan Bowman  
**Title:** Chemist, BP Chemistry

**Reviewed by:** Mark Crawford  
**Title:** Engineering Team Lead, BP Chemistry

**Signature:**

**Signature:**

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.