

## Design Number 3MU/AF 60-02

May 03, 2013

APPLIED FIREPROOFING

3M Company

3M™ Interam™ E-5, E-54-A and E-5A-4 Series Endothermic Mat


3M™ Fire Barrier CP 25WB+ Caulk

ASTM E 1725 (2008)

ASTM E 119 (2012)

Rating: 1 Hour

Approved for any cable fill



1. **CABLE TRAY:** Use nominal 6 in. wide x 4 in. deep galvanized steel ladder-back cable tray. Friction fit nominal 13/16 in. wide x 13/32 in. deep, 18 GA galvanized steel struts between side rails spaced 12 in. on center (oc) along the length of the cable tray. Use filament tape for additional support if needed.
2. **CERTIFIED MANUFACTURER:** 3M Company  
**CERTIFIED PRODUCT:** Applied Fireproofing  
**MODEL:** 3M™ Interam™ E-5, E-54-A and E-5A-4 Series Endothermic Mat  
**ENDOTHERMIC MAT:** Install 3 layers of foil faced flexible mat tightly around the cable tray (Item 1). Install each piece of mat with a minimum 2 in. overlap onto itself and temporarily hold in place using filament tape if needed.
  - A. **COLLAR:** Install nominal 4 in. wide strip of endothermic mat (Item 2) around outer layer of the wrapped cable tray (Item 1). Center collar over butt joints over outer layer and secure using steel banding (Item 5).
3. **CERTIFIED MANUFACTURER:** 3M Company  
**CERTIFIED PRODUCT:** Caulk or Sealant  
**MODEL:** 3M™ Fire Barrier CP 25WB+ Caulk  
**CAULK:** Install caulk between butt joints of endothermic mat (Item 2) on all layers. Alternative use is to fill gaps and voids along seams greater than 1/8 in. wide.
4. **TAPE:** (Not Shown) Apply 4 in. wide pressure sensitive tape with aluminum foil facing to all exposed edges of the collar (Item 2A) as well as the longitudinal (overlap) joints of the endothermic mat (Item 2) on the outer layer.
5. **STEEL BANDING:** Install 1/2 in. wide x 0.020 in. thick stainless steel banding on the outer layer of the endothermic mat (Item 2). Install banding within 1 in. of the edge of collars (Item 2A) and butt joints and maximum 12 in. oc at all other locations.

This material was extracted and drawn by 3M Fire Protection Products from the 2013 Product Directory, © Intertek

Flexible Wraps

Endothermic Mat

Applied Fireproofing

AF