

Technical Bulletin No.: T08-1002

Title: Compatibility of 3M Fire Barrier Sealants with

CPVC PIPE

Date: May 27, 2008

Issued By: Tom Floyd

TITLE:

COMPATIBILITY OF 3M FIRE BARRIER SEALANTS WITH CPVC PIPE

DESCRIPTION:

3M currently sells Fire Barrier Sealants for use on a variety of firestopping applications, including CPVC pipe. Because of various changes in the marketplace, we are clarifying our current recommendation of 3M products for use in applications with CPVC pipe. 3M has become aware of several new brands of CPVC pipe emerging in the market, making evaluation of compatibility with this material more complex. In addition, The Lubrizol Corporation had previously changed the internal test method by which they determine compatibility with CPVC piping. The changes to 3M's recommendations are not prompted by any formulation changes to 3M's[™] Fire Barrier Sealants that would adversely affect their compatibility with CPVC pipe.

3M PRODUCTS RECOMMENDED FOR USE WITH CPVC PIPE:

3M™ Fire Barrier Sealant IC 15WB+

3M[™] Fire Barrier Water Tight Sealant 3000 WT

3M[™] Fire Barrier Water Tight Sealant 1000 NS

3M PRODUCTS <u>NOT</u> RECOMMENDED FOR USE WITH CPVC PIPE:

3M™ Fire Barrier Sealant CP25WB+

3M™ Fire Barrier Sealant 1003 SL

3M™ Fire Barrier Sealant FD 150+

3M[™] Fire Barrier Sealant 2000+

3M™ Fire Barrier Sealant 2000

3M™ Fire Block Sealant FB 136

Approved third party systems for these products are being updated to reflect this recommendation.

THIS BULLETIN IS BEING SENT TO:

3M Fire Protection Products Authorized L-1 Direct Dealers
3M Fire Protection Products Authorized L-2 Distributors
3M Sales Representatives
3M Manufacturer's Representatives
3M St. Paul Internal
3M International

3M Building and Commercial Services Division3M Center, Building 223-2S-24