

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20201016- R9700  
**Report Reference** R9700  
**Issue Date** 2020-October-16

**Issued to:** 3M COMPANY 3M FIRE PROTECTION PRODUCTS  
3M CENTER  
SAINT PAUL, MN 55144-1001 USA

**This certificate confirms that  
representative samples of**

Fill, Void or Cavity Materials

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

ANSI/UL 1479, "Fire Tests of Penetration Firestops"  
Fourth Edition  
ANSI/UL 2079, "Tests for Fire Resistance of Building Joint  
Systems" - Fourth Edition  
ANSI/ASTM E2307, "Standard Test Method for Determining  
Fire Resistance of Perimeter Fire Barriers Using  
Intermediate-Scale, Multi-story Test Apparatus."

**Additional Information:**

See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20201016- R9700  
**Report Reference** R9700  
**Issue Date** 2020-October-16

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

FireDam™ Spray 200 for use in Joint System Nos. BW-S-0008, FF-D-0002, FF-D-0014, FF-D-1042, FW-D-0004, FW-D-0011, FW-D-1040, HW-D-0020, HW-D-0021, HW-D-0022, HW-D-0023, HW-D-0029, HW-D-0030, HW-D-0031, HW-D-0038, HW-D-0040, HW-D-0101, HW-D-0118, HW-D-0122, HW-D-0123, HW-D-0192, HW-D-0248, HW-D-0265, HW-D-0376, HW-D-0379, HW-D-0384, HW-D-0385, HW-D-0447, HW-D-0465, HW-D-0478, HW-D-0479, HW-D-0552, HW-D-0575, HW-D-0604, HW-D-0633, HW-D-0755, HW-D-0807, HW-D-1010, HW-D-1020, HW-D-1059, HW-D-1079, HW-D-1080, HW-D-1123, WW-D-0215, WW-D-0227, WW-D-0228, WW-D-1202, WW-D-1203, WW-D-1204, WW-D-1239, WW-D-1240, WW-D-1241.

FireDam™ Spray 200 for use in Perimeter Fire Containment System Nos. CW-D-1017, CW-D-2055, CW-S-2004, CW-S-2005, CW-S-2007.

FireDam™ Spray 200 for use in Through-Penetration Firestop System Nos. C-AJ-1275, C-AJ-8106, W-L-8033, W-L-8034.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

