

# Certificate of Compliance

Certificate Number **20110819-R9700C**  
Report Reference **2011 August 19**  
Issue Date **2011 August 19**

Page 1 of 2



**Issued to:** 3M Company

3M Center  
St Paul, MN 55144

*This is to certify that  
representative samples of*

**Fill, Void or Cavity Materials**  
FireDam Spray 200  
(Manufactured in United States of America)

SEE ADDENDUM PAGE 2

*Have been investigated by Underwriters Laboratories Inc.® (UL) or any authorized licensee of UL in accordance with the Standard(s) indicated on this Certificate.*

**Standard(s) for Safety:**

ANSI/UL 1479, "Fire Tests of Through-Penetration Firestops,"  
ANSI/UL 2079, "Tests for Fire Resistance of Building Joint Systems"

**Additional Information:**

See UL On-Line Certification Directory at [www.UL.com](http://www.UL.com) for additional information.

**Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.**

The UL Classification Mark includes: UL in a circle symbol:  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product category name (product identity) as indicated in the appropriate UL Directory.

**Look for the UL Classification Mark on the product**

**William R. Carney**

**Director, North American Certification Programs**

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://www.ul.com/global/eng/pages/corporate/contactus/>

# Certificate of Compliance

Certificate Number **20110819-R9700C**  
Report Reference **2011 August 19**  
Issue Date **2011 August 19**

Page 2 of 2



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

FireDam™ Spray 200 for use in Joint System Nos. BW-S-0008, FF-D-0002, FF-D-0014, FF-D-1042, FW-D-0004, FW-D-0011, FW-D-1040, HW-D-0020, HW-D-0021, HW-D-0022, HW-D-0023, HW-D-0029, HW-D-0030, HW-D-0031, HW-D-0038, HW-D-0040, HW-D-0101, HW-D-0118, HW-D-0122, HW-D-0123, HW-D-0192, HW-D-0248, HW-D-0265, HW-D-0376, HW-D-0379, HW-D-0384, HW-D-0385, HW-D-0447, HW-D-0465, HW-D-0478, HW-D-0479, HW-D-0552, HW-D-0575, HW-D-0604, HW-D-0633, HW-D-1010, HW-D-1020, HW-D-1059, HW-D-1079, HW-D-1080.

FireDam™ Spray 200 for use in Perimeter Fire Containment System Nos. CW-D-2055, CW-S-2004, CW-S-2005, CW-S-2007.

FireDam™ Spray 200 for use in Through-Penetration Firestop System No. C-AJ-1275, C-AJ-8106, W-L-8033, W-L-8034.

**William R. Carney**

**Director, North American Certification Programs**

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://www.ul.com/global/eng/pages/corporate/contactus/>