

Certificate of Compliance

Certificate Number 20050531-R9700
Report Reference R9700, May 31, 2005
Issue Date 2005 May 31

Page 1 of 1



Issued to: **3M Company**

3M Center
St Paul, MN 55144

*This is to certify that
representative samples of*

Fill, Void or Cavity Materials
FB-2001 Foam

*Have been investigated by Underwriters Laboratories Inc.® in
accordance with the Standard(s) indicated on this Certificate.*

Standard(s) for Safety:


ANSI/UL 1479, Fire Tests of Through-Penetration Firestops
ANSI/UL 2079, Tests for Fire Resistance of Building Joint Systems.

Additional Information:

FB-2001 Foam for use in Joint System No. FF-S-0001.

FB-2001 Foam for use in Through Penetration Firestop System Nos. C-BJ-0019, C-BJ-8008, W-J-0003, W-J-1023, and W-J-4008.

Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.

The UL Classification Mark includes: UL in a circle symbol  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product category name (product identity) as indicated in the appropriate UL Directory.

Look for the UL Classification Mark on the product

Issued by:

Mona Couloute
Mona Couloute

Underwriters Laboratories Inc.

Reviewed by:

Richard N. Walke
Richard Walke

Underwriters Laboratories Inc.



**Underwriters
Laboratories Inc.®**

Northbrook Division
333 Pfingsten Road
Northbrook, IL 60062-2096 USA
www.ul.com
tel: 1 847 272 8800

May 31, 2005

3M Company
Attn: Mr. Brandon Cordts
3M Center
St Paul, MN 55144

Our Reference: R9700

Subject: Certificate of Compliance

Dear Mr. Cordts:

As you requested, we have prepared a new Certificate of Compliance for your Company, 3M Company. We have opened a Project with a cost limit of \$600.00 to cover our charges. This letter and the attached Certificate of Compliance complete our work under Project 05NK14051.

Very truly yours,

Monna Couloute
MONA COULOUTE
Project Handler
Fire Protection Division

Reviewed By:

Richard W. Walke
Richard Walke
Staff Engineer
Fire Protection Division

An independent organization working for a safer world with integrity, precision and knowledge
An independent organization working for a safer world with integrity, precision and knowledge

