

# Certificate of Compliance

Certificate Number **20081205-R9700G**  
Report Reference **2008 December 5**  
Issue Date **2008 December 5**

Page 1 of 2



*Issued to:* **3M Company**

3M Center  
St Paul, MN 55144

*This is to certify that  
representative samples of*

**Fill, Void or Cavity Materials**  
Fire Barrier 2000 Caulk

*Have been investigated by Underwriters Laboratories Inc.® (UL) or any authorized  
licensee of UL in accordance with the Standard(s) indicated on this Certificate.*

*Standard(s) for Safety:*

ANSI/UL 1479 Fire Tests of Through-Penetration Firestops  
ANSI/UL 2079 Tests for Fire Resistance of Building Joint Systems

*Additional Information:*

See addendum for system listings

**Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.**

The UL Classification Mark includes: UL in a circle symbol:  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product category name (product identity) as indicated in the appropriate UL Directory.

**Look for the UL Classification Mark on the product**

Issued by:

*Mona Couloute*  
Mona Couloute

Underwriters Laboratories Inc.

Reviewed by:

*Steven Hoffman*  
Steven Hoffman

Underwriters Laboratories Inc.

# Certificate of Compliance

Certificate Number **20081205-R9700G**

Report Reference **2008 December 5**

Issue Date **2008 December 5**

Page 2 of 2



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

FB-2000 Caulk for use in Joint System Nos. BW-S-0007, FF-D-1002, FF-D-1003, FF-S-0001, FF-S-1001, FF-S-1003, FW-D-1002, FW-D-1003, HW-D-0060, HW-D-0061, HW-D-0118, HW-D-0119, HW-D-0120, HW-D-1002, HW-D-1003, HW-D-1011, HW-D-1012, HW-D-1020, HW-S-0002, HW-S-0005, HW-S-0007, HW-S-0040, HW-S-0041, HW-S-0042, WW-D-1003, WW-D-1004, WW-S-0001, WW-S-0004, WW-S-1001 and WW-S-1003.

FB-2000 Caulk for use in Through-Penetration Firestop System Nos. C-AJ-0008, C-AJ-1009, C-AJ-1013, C-AJ-1014, C-AJ-1058, C-AJ-2019, C-AJ-3029, C-AJ-3041, C-AJ-5009, C-AJ-5041, C-AJ-6002, C-AJ-8003, F-C-1003, F-C-3002, W-L-1009, W-L-1010, W-L-3009, W-L-3041 and W-L-5032.

Issued by:

*Mona Couloute*  
Mona Couloute

Underwriters Laboratories Inc.

Reviewed by:

*Steven Hoffman*

Steven Hoffman

Underwriters Laboratories Inc.