



10/14/2013

Mr. Ernie Schmidt  
3M COMPANY  
3m Center  
Saint Paul, MN Us 55144-1001

Reference: File R9700, R9269      Project 4786054389  
Subject: Letter Report for Product status – Aging Review Program

Dear Mr. Schmidt,

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL.

This letter will confirm that the 3M Fire Barrier Rated Foam, FIP 1-Step product has been found to comply when tested at our Northbrook facility in accordance with the Environmental Exposure / Accelerated Aging Protocol, in the Third Edition of the Standard for Fire Test of Through-Penetration Firestops ANSI/UL 1479, with revisions dated October 19, 2012.

This letter will serve to report that all tests on the subject product have been completed with acceptable results.

This completes the work anticipated under Project 4786054389 and we are closing the project with this letter.

Should you have any questions or comments concerning the above, please feel free to contact the undersigned.

Sincerely,

A handwritten signature in black ink, appearing to read 'J. Smyser', written over a white background.

Jim Smyser  
Senior Project Engineer  
Department: 3019AFPD  
E-mail: james.p.smyser@ul.com

UL LLC  
333 Pfingsten Road, Northbrook, IL 60062-2096 USA  
T: 847.272.8800 / F: 847.272.8129 / W: UL.com

James P  
Smyser

Digitally signed by James P. Smyser  
DN: cn=James P. Smyser, o=UL LLC, ou=Engineering,  
ou=3M, ou=US, email=james.p.smyser@ul.com,  
c=US

Date: 2013.10.14 14:26:27 -0500